



Meiners Electric, Company Safety Manual

PAGE: 1 of 1

LAST REVISION:

December 9th, 2009

REVIEWED BY:

L. Kirk Berglund, Safety Director

FORM REF No:

SP-P-GASCYL

SUBJ:

Compressed Gas Cylinders

1. COMPRESSED GAS CYLINDERS

1. All gas cylinders shall have their contents clearly marked on the outside of each cylinder.
2. Cylinders must be placed and secured in an upright position, including storage and transfer.
3. Cylinder valves must be protected with caps or guards when not in use.
4. All leaking or defective cylinders must be removed from service promptly; tagged as inoperable and placed in an open space removed from the work area.
5. All operators are required to inspect equipment prior to utilization.
6. Oxygen and gas cylinders placed in storage are to be kept 20 feet apart or have a fire barrier between them.

Full and empty cylinders are to stored separately and protected from excess heat, snow, ice or physical damage.